

## Metering Requirements

B9.6 "Please confirm that there is metering in place with at least 15mins/ 30mins interval resolution for each proposed flexible service asset/unit located at the same measurement point as the meter fitted by the Relevant Meter Operator, compliant with Measuring Instruments Directive, to enable ESBN to monitor provision of flexibility services.

OR

Please confirm that there is either a QH interval meter or smart meter at the location of each proposed flexible service asset(s)/unit(s) fitted by the Relevant Meter Operator" "(a) Yes, there is customer metering in place for each asset with 15 or 30min resolution.

(b) Yes, there is an ESB Networks QH or Smart meter in place for each asset

No" "Yes to (a) or (b) = Pass

No = Fail"