



24 April 2020

Project No. 19126590.L60.A.1

ESB Networks

Engineering and Major Projects
One Dublin Airport Central
Dublin Airport
Cloghran
County Dublin
K67 XF72

RE ESB SITE 60 PEMBROKE TO RINGSEND 38KV CABLE FLUID LOSS: RECOMMENDATIONS

To whom it may concern

ESB Engineering and Major Projects (ESB) commissioned Golder Associates Ireland Limited (Golder) to complete a Preliminary Site Assessment (PSA) for historical loss of fluid from a high voltage (38 kV) cable run located between Pembroke and Ringsend, Dublin ('Site 60') (hereafter referred to as the 'Site').

The PSA was produced in-line with current EPA guidance (*Guidance on the management of contaminated land*, 2013). The findings of the PSA were presented in our report reference 19126590.60.A.2 dated 24 April 2020.

The risk assessment completed for this loss did not identify viable pollutant linkages. No further work is considered necessary for this site in relation to the loss of cable fluid in 2004 as identified in the report referenced above.

Yours sincerely,

Golder Associates Ireland Limited


Senior Hydrogeologist


Geo Environmental Director

EMcA/TM/mb